

Posting Date: March 12, 2024

ADDENDUM #1

East Hartford Public Schools Invitation to Bid #1858-24 O'Brien School Roof Replacement

The following changes, revisions, and/or additions are hereby made a part of the Contract Documents and shall supersede previously issued documents and shall become a part of the contract documents.

Date: March 11, 2024

1. Information to Bidders:

The Contractor shall be responsible to raise (remove and replace as required) all existing roof top mounted insulated refrigerant lines and conduit including, but not limited to, gas free and recharge HVAC refrigerant lines. Reinstall all roof top HVAC lines in accordance with the contract documents and all applicable codes. The Contractor shall include all cost associated with this work in the base bid. The East Hartford Board of Education has this equipment serviced by:

Tucker Mechanical
795 Brook Street
Rocky Hill, Ct 06067
Paul Wielock, Special Projects Group Manager
203-630-7267
pwieloch@emcor.net

2. Information to Bidders:

Clarification: The tapered insulation system shall consist of a 2.7" flat stock base layer of polyisocyanurate insulation with a ¼" per ft. tapered polyisocyanurate insulation installed on top of the base layer. The tapered insulation system shall start with a minimum depth of 1-1/2" at the low/valley point. The minimum depth of the tapered polyisocyanurate insulation system shall be 4.2". The Contractor shall be responsible install the polyisocyanurate insulation in accordance with all requirements of the contract documents and applicable codes.

3. Roof Access Hatchway: A picture of the wall location where the new hatchway ladder/access will be installed as specified in the drawings is included in this addendum.

Hatchway LADDER Location



End of Addendum #1

ADDENDUM #1

**East Hartford Public Schools
Invitation to Bid #1856-24
O'Brien School Roof Replacement
Bidder Acknowledgement**

Addendum #1 Includes the following:

- a. Information to Bidders #1*
- b. Information to Bidders #2*
- c. Hatchway ladder location picture*

**Bidders must acknowledge and include this Addendum page as part of
their bid package. The bidder acknowledges receipt of Addendum #1:**

Date: _____

Name of Bidder: _____

Title: _____

Address: _____